BEFORE THE NATIONAL GREEN TRIBUNAL EASTERN ZONE BENCH, KOLKATA

O.A. No. 114/2015/EZ

SUBRATO MOOKHERJEE

VS

GENERAL MANAGER, KOLAGHAT THERMAL POWER STATION & ORS

CORAM:

Hon'ble Mr. Justice S.P.Wangdi, Judicial Member

	Applicant : None Respondent No. 1 & 4 : Mr. Anindya Mitra, Sr. Advocate
C	Respondent No. 1 & 4 : Mr. Anindya Mitra, Sr. Advocate Mr. N.C.Bihani, Advocate
	Respondent No. 2 & 5 : Mr. Rajib Roy, Advocate
	Respondent No. 3 : Mr. Dipanjan Ghosh, Advocate
	Respondent No. 6 : Mr. Surendra Kumar, Advocate
	espondent No. 7 : Mr. Kallol Basu, Advocate
	Mr. Nilanjan Pal, Advocate
11	
	Orders of the Tribunal
Date & Remarks	
Item No. 3	
14 th December	
2017.	The reports of the Central Pollution Control
2017.	R SIA
	Board, the Respondent No. 6, the State PCB,
	board, the Respondent No. 0, the State PCD,
	Provide and the second se
	Respondent No. 3 and the affidavit on behalf of the
	I RIDU.
	respondent No. 1, on the emission level as directed
	vide order dated 15.11.2017, filed by Mr. Surendra
	Kumar, Ld. Advocate and Mr Sibojyoti Chakraborti, Ld.
	Advecate, are ordered to be taken on record
	Advocate, are ordered to be taken on record.
	The two reports indicate different views inasmuch as

while in the report of the CPCB ,mentions the pollution level of the Plant during the forenoon and afternoon as being far above 100 mg/Nm³ the one filed by the SPCB shows it to be much below the upper mark of 100 mg/Nm³ at 53,26 mg/Nm³.

In order to resolve this discrepancy, Mr. A. Mitra, Ld. Sr. Advocate for the Respondent Power Plant, suggests constitution of a joint committee consisting of members of both the CPCB and State PCB which would once again ascertain the emission level. We find the suggestion to be acceptable and accordingly direct the CPCB and PCB to constitute a team consisting of one Senior Scientist each from the two Boards. The team shall once again check the emission level and ascertain as to whether it complies with the prescribed level of emission at 100 mg/Nm³ as required under the guidelines prescribed by the MOEF as this was expected to be achieved by 7.12.2017. In order to facilitate such inspection for assessment, Unit No. 2 is permitted to run on trial basis for two weeks and thereafter the



