

**BEFORE THE NATIONAL GREEN TRIBUNAL  
PRINCIPAL BENCH, NEW DELHI**

(By Video Conferencing)

Original Application No. 1002/2018

(With reports dated 15.09.2020 & 05.11.2020 filed by NOIDA and reports dated 15.05.2020 and 29.10.2020 filed by CPCB)

Abhisht Kusum Gupta

Applicant

Versus

State of Uttar Pradesh & Ors.

Respondent(s)

Date of hearing: 06.11.2020

**CORAM: HON'BLE MR. JUSTICE ADARSH KUMAR GOEL, CHAIRPERSON  
HON'BLE MR. JUSTICE SHEO KUMAR SINGH, JUDICIAL MEMBER  
HON'BLE DR. SATYAWAN SINGH GARBYAL, EXPERT MEMBER  
HON'BLE DR. NAGIN NANDA, EXPERT MEMBER**

Applicant: Mr. Abhisht Kusum Gupta, Applicant in person

Respondent(s): Mr. Aman Bhalla, Advocate for CPCB  
Mr. Ravindra Kumar, Advocate for NOIDA Authority  
Mr. Pradeep Misra and Mr. Daleep Dhyani, Advocates for UPPCB  
Mr. Sumeet Pushkarna, Advocate for DJB  
Mr. Balendu Shekhar, Advocate for EDMC and DPCC  
Mr. Vishwajit Singh, Advocate for GNN

**ORDER**

1. The issue for consideration is the remedial action for preventing untreated sewage going to the "irrigation canal" in Sector 137, NOIDA. One of the major reasons for discharge of untreated sewage is deficient STPs in 95 high rise buildings in Noida, apart from such discharge at some other locations.

2. The matter has been dealt with by various orders in the last two years, in the light of the reports of the Committee appointed by the

Tribunal, acknowledging deficiencies and recommending further action. In the report of CPCB dated 01.11.2019, steps to be taken by NOIDA, Ghaziabad Nagar Nigam, Delhi Jal Board (DJB), East Delhi Municipal Corporation (EDMC) and Nagar Palika Parishad, Khoda Makanpur were mentioned as follows:-

| <b>Sl. No</b> | <b>Department</b>                    | <b>Directions issued u/s 5 of EPA, 1986</b>   |
|---------------|--------------------------------------|---|
| 1.            | NOIDA                                | <ul style="list-style-type: none"> <li><i>i. To develop time bound action plan to stop discharge of untreated wastewater to 30 drains.</i></li> <li><i>ii. To intercept all drains and channelize wastewater to STPs so that no untreated wastewater is discharged to Noida drain.</i></li> <li><i>iii. To deposit an Interim Environmental Compensation of Z 1,00,00,000</i></li> </ul>  |
| 2.            | Ghaziabad Nagar Nigam                | <ul style="list-style-type: none"> <li><i>i. To establish sewerage network and treatment facility to treat sewage generated from Khoda village.</i></li> <li><i>ii. To Deposit an Interim Environmental Compensation of 1,00,00,000</i></li> </ul>  |
| 3.            | DJB                                  | <ul style="list-style-type: none"> <li><i>i. To initiate legal proceedings against the residents of GD colony, Gharauli village and Kondli village, Delhi having failed to take sewer connections.</i></li> <li><i>ii. To ensure that each building under their jurisdiction shall have sewer connection so that current practice of discharge of untreated sewage into storm water drainage system should be stopped.</i></li> </ul> |
| 4.            | EDMC                                 | <ul style="list-style-type: none"> <li><i>i. To direct dairy farms to develop decentralized treatment facility so that their untreated waste shall not be discharged to DDA drainage system</i></li> <li><i>ii. To ensure that untreated dairy waste including animal dungs from Gharuli village should not be discharged into storm water drain. Challan / Legal action shall be initiated against such violators.</i></li> </ul>    |
| 5.            | Nagar Palika Parishad Khoda Makanpur | <i>Show cause notice issued to explain the reasons as to why action should not be taken against Nagar Palika Parishad Khoda including levying of Environmental Compensation for discharge of untreated sewage to drainage system of Delhi. Copy of directions is attached as Annexure-I</i>   |

3. The report further stated that CPCB called a meeting of the concerned Authorities and conducted inspection noticing high level of water pollution in the drains as follows:-

**Table 1: Analytical Results of Drain**

| Si. No.   | Sample Location  | Physico-Chemical Parameters |     |     |     | Bacteriological Parameters              |   |
|---|--|-----------------------------|-----|-----|-----|---|---|
|   |  | pH                          | COD | BOD | TSS | Total Coliform (MPN/100m <sup>1</sup> ) | Fecal Coliform (MPN/100m <sup>1</sup> ) |
| <b>Water Quality of Noida Drain at different locations</b>                |  |                             |     |     |     |   |   |
| 1.  | Budh Vihar, Sector-11, Noida   | 7.56                        | 444 | 219 | 330 | 13 X10 <sup>6</sup>                     | 79 X10 <sup>5</sup>                     |
| 2.  | S-14, New Kondli Road, Sector-11, Noida.   | 7.55                        | 433 | 217 | 352 | 23 X10 <sup>6</sup>                     | 23 X10 <sup>6</sup>                     |
| 3.  | Sector-50, Noida Link Road.  | 7.72                        | 169 | 68  | 84  | 11 X10 <sup>6</sup>                     | 68 X10 <sup>5</sup>                     |
| 4.  | Sector-137, India TV Metro Station, Noida.   | 7.78                        | 186 | 71  | 65  | 13 X10 <sup>6</sup>                     | 13 X10 <sup>6</sup>                     |
| 5.  | Noida drain at regulator   | 7.84                        | 145 | 60  | 89  | -                                       | -                                       |
| 6.  | Noida drain at before Confluence with river Yamuna                                 | 7.82                        | 163 | 46  | 83  | 78 X10 <sup>5</sup>                     | 78 X10 <sup>5</sup>                     |
| <b>Water Quality of adjoining drains of Noida Drain</b>                   |  |                             |     |     |     |   |   |
| 7.  | Khoda village  | 7.54                        | 314 | 107 | 194 | 78                                      | 20 X10 <sup>5</sup>                     |
| 8.  | Drain merges with Noida drain at Sector-142, Advant Navis Buisness IT Park, Noida. | 7.70                        | 182 | 100 | 63  | 46 X10 <sup>6</sup>                     | 46 X10 <sup>6</sup>                     |
| <i>Note: All units are measured in mg/l except Fecal Coliform and pH.</i> |  |                             |     |     |     |   |   |

*BOD concentration at entrance of NOIDA, U.P is 219 mg/1 whereas Fecal coliform count is 20 X 10<sup>5</sup>. However, concentration of BOD before confluence point is 46 mg/1 and Fecal coliform count is 78 X 10<sup>5</sup> MPN/100 ml. The results indicate that although there is marginal improvement in water quality as the drain travels through NOIDA but still concentration level of BOD and Fecal Coliform at the confluence point of drain with Yamuna is quite high.”*

4. The action taken report and recommended further action were in the form of following table:-

**“4.0 SUMMARY OF ACTION TAKEN BY CONCERNED AGENCIES**

*Based on the inspection made, analytical results of the samples collected from drains and action taken report of concerned agencies, summarized report is placed below:*

| <b>Si. No</b> | <b>Department</b> | <b>Directions of CPCB and NGT</b>   | <b>Status report</b>  | <b>Recommendations</b>  |
|---------------|-------------------|---|---|---|
| <b>1.</b>     | NOIDA             | <ul style="list-style-type: none"> <li>i. To develop time bound action plan to stop discharge of</li> <li>ii. To intercept all drains and channelize wastewater to STPs so that no untreated wastewater is discharged to Noida drain.</li> <li>iii. To deposit an Interim Environmental Compensation of Rs. 1,00,00,000</li> <li>iv. Hon'ble NGT directed to submit furnish performance guarantees in the sum of Rs. 1 crore each to the satisfaction of CPCB undertaking to take remedial actions in terms of the directions of the CPCB, failing which the said amount will be forfeited</li> </ul> | <ul style="list-style-type: none"> <li>i. Noida authority made representation against the direction and EC imposed by CPCB on 01/07/2019. Copy attached as <b>Annexure-V.</b></li> <li>ii. Reply of representation was made on 19/07/2019 and hearing was conducted on 23/07/2019 and Noida authority was further directed to ensure compliance of CPCB directions.</li> <li>iii. Representative of NOIDA has informed during the meeting on 01.10.2019 that committees being constituted for identification and taking action on high rise buildings discharging untreated waste and to identify villages which are discharging waste into drain</li> <li>iv. <b>Action plan in compliance to direction issued not submitted till date</b></li> <li>v. Environment Compensation was not submitted till date.</li> <li>vi. Performance Bank Guarantee not submitted till date.</li> </ul> | Noida authority shall prepare time bound action plan either to discharge of untreated waste throughaforesaid 30 drains. Alternatively, all such drains be intercepted and taken to STPs so that no untreated wastewater flows to Noida drain. |

|   |                       |   |  |  |
|---|-----------------------|---|--|--|
| 2 | Ghaziabad Nagar Nigam | <p>i. To establish sewerage network and treatment facility to treat sewage generated from Khoda village.</p> <p>ii. To Deposit an Interim Environmental Compensation of 1,00,00,000</p> <p>iii. Hon'ble NGT directed to submit furnish performance guarantees in the sum of Rs. 1 crore each to the satisfaction of CPCB undertaking to take remedial actions in terms of the directions of the CPCB, failing which the said amount will be forfeited</p> | <p>i. Ghaziabad Nagar Nigam vide letter dated 24.06.2019 clarified that the Khora village falls under the jurisdiction of Nagar Palika Parishad Khoda Makanpur. Copy attached as Annexure-VI.</p> <p>ii. Accordingly, show cause notice issued to Nagar Palika Parishad Khoda Makanpur vide letter dated 24.09.2019.</p> |  |
|---|-----------------------|---|--|--|

|    |     |  |  |   |
|----|-----|--|--|---|
| 3. | DJB | <p>i. To initiate legal proceedings against the residents of GD colony, Gharauli village and Kondli village, Delhi having failed to take sewer connections.</p> <p>ii. To ensure that each building under their jurisdiction shall have sewer connection so that current practice of discharge of untreated sewage into storm water drainage system should be stopped.</p> <p>iii. Hon'ble NGT directed to submit furnish performance guarantees in the sum of Rs. 1 crore each to the satisfaction of CPCB undertaking to take remedial actions in terms of the directions of the CPCB, failing which the said amount will be forfeited</p> | <p>i. Action plan of DJB was received vide letter dated 22/07/2019. Copy of letter is attached as <b>Annexure-VII.</b></p> <p>ii. Representative of Delhi Jal Board informed that special camps were organized residents to take sewer connection.</p> <p>iii. 732 number of notice issued to residents of Kondli and Gharauli. It was also informed that 3 drains of PWD carrying wastewater shall be tapped and conveyed to Kondli STPs for treatment. Interception of drains will be finished by December, 2019.</p> <p>v. Performance Bank Guarantee not submitted till date</p> | <p>i. DJB shall expedite and complete the interception of 03 adjoining drain in Delhi segment by December, 2019.</p> <p>ii. DJB should initiate legal proceedings against residents of GD colony, Gharauli village and Kondli village on account of their reluctance and failure to take sewerage connections.</p> <p>iii. DJB shall ensure that each building under their jurisdiction shall have sewer connection so that current practice of discharge of untreated sewage into storm water drainage system should be stopped.</p> |
|----|-----|--|--|---|

|    |                                      |   |  |   |
|----|--------------------------------------|---|--|---|
| 4. | EDMC                                 | <p>i. To direct dairy farms to develop decentralized treatment facility so that their untreated waste shall not be discharged to DDA drainage system.</p> <p>ii. To ensure that untreated dairy waste including animal dungs from Gharuli village should not be discharged into storm water drain. Challan/Legal action shall be initiated against such violators.</p> <p>iii. Hon'ble NGT directed to submit furnish performance guarantees in the sum of Rs. 1 crore each to the satisfaction of CPCB undertaking to take remedial actions in the terms of the directions of the CPCB, failing which the said amount will be forfeited.</p> | <p>i. EDMC has informed during the meeting that 591 Challan issued to residents of Kondli and Gharauli for disposing their wastewater into drain and Show-Cause notice is also issued to illegal dairies for discharging waste in drain.</p> <p>ii. East Delhi Municipal Corporation Veterinary Services Department Vide email dated 31/10/2019 provided the action taken report indicating action taken against the illegal dairy farms at Gharoli colony. Copy attached as <b>Annexure-VIII.</b></p> <p>iii. Performance Bank Guarantee was not submitted. However, it was informed that same was approved by Competent Authority and will be submitted in one</p> | <p>i. EDMC should ensure that untreated dairy waste including animal dungs from Gharuli village should not be discharged into storm water drain. Challan / Legal action shall be initiated against such violators.</p> <p>ii. The dairy farms be shifted to outskirts of the area in a time bound manner.</p>                                   |
| 5. | Nagar Palika Parishad Khoda Makanpur | <p>Show cause notice issued to explain the reasons as to why action should not be taken against Nagar Palika Parishad Khoda including levying of Environmental Compensation for discharge of untreated sewage to drainage system of Delhi.</p>  | <p>i. Executive officer of Khoda Nagar Parishad has informed during the meeting that at present there is no infrastructure facility to treat and tap waste from Khoda colony.</p> <p>ii. Further, no reply received till date.</p>   | <p>i. Khoda Nagar Palika should developed facility to tap untreated water of Khoda village and should discharge only treated water to drainage system of Delhi.</p> <p>ii. Directions for submission of performance guarantee in the sum of Rs. 1 crore by Ghaziabad Nagar Nigam to CPCB may refer to Nagar Palika Parishad Khoda Makanpur.</p> |

5. The Tribunal directed action to be taken by the concerned authorities accordingly and further observed as follows:-

*“5. The CPCB has further recommended as follows:*

*“Based on observation made by the inspection team including Dr. C.R. Babu, it is further recommended that in-situ treatment of Noida drain in Noida stretch be carried out as immediate measure for treatment of wastewater of NOIDA drain.*

*As, the Noida drain falls under the jurisdiction of UP Irrigation Flood Control Department and it is suggested that in-situ treatment may be carried out jointly be NOIDA authority and UP Irrigation Flood Control Department in consultation with Dr. C.R. Babu.”*

*6. In view of above, UP Irrigation Flood Control Department and NOIDA Authority may take further remedial action expeditiously which may be overseen by the Principal Secretary, UP Irrigation and Flood Control Department and the Chairman, NOIDA Authority. The Chairman, NOIDA Authority will act as a nodal agency for coordination and compliance which may be further overseen and coordinated by the CPCB.*

*7. The CPCB may furnish a status report in the matter before the next date by e-mail at [judicial-ngt@gov.in](mailto:judicial-ngt@gov.in).”*

6. In pursuance of above, NOIDA has filed reports dated 15.09.2020 and 05.11.2020 while CPCB reports are dated 15.05.2020 and 29.10.2020. It will be suffice to refer to the last reports of NOIDA and CPCB. The report of the CPCB dated 29.10.2020 is as follows:-

***“ ACTION TAKEN BY CPCB***

*In compliance to the directions of Hon'ble NGT, CPCB has taken following action:*

*1. Directions of Hon'ble NGT communicated to CEO, NOIDA vide letters dated 19/03/2020, 12/05/2020 and 13/08/2020 to provide progress report in the matter. Copy of letter is attached as Annexure-I.*



2. NOIDA vide letter dated 15/09/2020 has submitted updated action taken report and future action plan to CPCB for abatement of pollution of NOIDA drain. Copy of letter is attached as Annexure II

3. **Further, CPCB has examined the proposed action plan and observations communicated to NOIDA authority vide letter dated 28/09/2020.** Copy of letter is attached as Annexure-III.

4. **CPCB communicated to Principal Secretary, Urban Development, Uttar Pradesh vide letter dated 28/09/2020 for submission of action plan for treatment of wastewater discharging from Khora Nagar Palika.** Copy of letter is attached as Annexure-IV. Reply is still awaited.

5. CPCB also requested Delhi Jal Board (DJB) and East Delhi Municipal Corporation vide letter dated 28/09/2020 to submit the status report on action plan of untreated sewage of Kondli and Gharoli area (Delhi Catchment area) into Kondli drain. Copy of letter is attached as Annexure-V

6. Delhi Jal Board vide letter dated 15/10/2020 informed that as per action plan trapping of drains contributing wastewater discharge into Kondli drain from Delhi catchment was completed in January, 2020. Copy of letter is attached as Annexure-VI.”

7. The report of NOIDA dated 05.11.2020 is as follows :

| Sr.     | Action plant with proposed timelines as submitted before   | Follow up action  |   |                   |          |            |    |  |                    |   |
|---------|--|---|---|-------------------|----------|------------|----|--|--------------------|---|
|         | <p>A Committee has been constituted to inspect high rise building's STP and to evaluate the performance of every STP. The Committee will examine whether the STP to perform standard parameter. It operates in a compliance manner and discharges only the treated effluent in the passing drain, post utilizing the treated waste-water at their end. The defaulters are to be identified and recommended for environment compensation for non-compliance of NGT orders. More stringent action will be taken against the builders as per NOIDA authority rules (Time required</p> | <p><b>1).The committee as constituted by the NOIDA AUTHORITY has made:: inspection at 57 high rise societies. There are total 95 nos. of Grodp: Housing Societies out of which 43 nos. of project are completed and 52' nos. of societies have got partial occupancy certificate. The inspection of 55 percent high rise societies has been completed. Status report of their STPs are as follows:-</b></p> <table border="1" data-bbox="857 2091 1422 2392"> <thead> <tr> <th data-bbox="857 2091 922 2145">Sr. No.</th> <th data-bbox="922 2091 1110 2145">Name of Societies</th> <th data-bbox="1110 2091 1235 2145">Location</th> <th data-bbox="1235 2091 1422 2145">STP Status</th> </tr> </thead> <tbody> <tr> <td data-bbox="857 2145 922 2392">1.</td> <td data-bbox="922 2145 1110 2392">M/s Granite Great Properties Ltd. C-23, Greater Kailash Enclave, Part - I, New Delhi</td> <td data-bbox="1110 2145 1235 2392">GH-03 Sector - 100</td> <td data-bbox="1235 2145 1422 2392">Sewage is being discharge in open drain. Notice has been issued by Noida authority and discharge of untreated</td> </tr> </tbody> </table> | Sr. No.   | Name of Societies | Location | STP Status | 1. | M/s Granite Great Properties Ltd. C-23, Greater Kailash Enclave, Part - I, New Delhi | GH-03 Sector - 100 | Sewage is being discharge in open drain. Notice has been issued by Noida authority and discharge of untreated |
| Sr. No. | Name of Societies  | Location  | STP Status  |                   |          |            |    |  |                    |   |
| 1.      | M/s Granite Great Properties Ltd. C-23, Greater Kailash Enclave, Part - I, New Delhi   | GH-03 Sector - 100  | Sewage is being discharge in open drain. Notice has been issued by Noida authority and discharge of untreated |                   |          |            |    |  |                    |   |

|           |     |  |   |
|-----------|-----|--|---|
| - 1 year) |     |  | <i>sewage has been stopped.</i>   |
|           | 2.  | <i>M/s Paras Season Haven Pvt. Ltd. GH01D, Sector 168, Noida (Paras Season Society)</i>                                | <i>GH-01D Sector - 168</i><br><i>Discharging sewage in open drain. Penalty of Rs. 80, 000/- has been imposed for violation of NGTs Environmental norms. Discharge of untreated sewage has been stopped.</i> |
|           | 3.  | <i>M/s Supertech Ltd. plot No. B 28&amp;29, Sector 58, NOIDA (Supertech Capetown)</i>                                  | <i>GH-1A Sector- 74</i><br><i>STP is functional but not performing standard norms.</i>  |
|           | 4.  | <i>M/s Skytech Construction Pvt. Ltd. Plot No. GH-01D Sector 76 NOIDA (Skytech Matrott)</i>                            | <i>GH 01D Sector - 76</i><br><i>STP Construction is not completed so non-functional and locked.</i>   |
|           | 5.  | <i>M/s Amrapali Silicon City</i>   | <i>Sector 76</i><br><i>Untreated sewage is being discharged into drain from back side of society through long pipeline</i>  |
|           | 6.  | <i>Assotech Windsor Court</i>  | <i>Sector 78</i><br><i>STP not constructed</i>  |
|           | 7.  | <i>M/s Antkriksh Developers and Promoters Pvt. Ltd., Plot no. GH - 05A, Sector 78, NOIDA (Antriksh Golf View - II)</i> | <i>GH -05A Sector 78</i><br><i>STP functional but not properly maintained</i>   |
|           | 8.  | <i>M/s Sunshine Infrawell Pvt. Ltd. Plot No. GH-05B Sector 78, Noida (Sunshine Helion)</i>                             | <i>GH-05B Sector 78</i><br><i>Constructed but not functional</i>  |
|           | 9.  | <i>M/s G.S. protors Pvt. Ltd. GH-01 C, Sector 78 Noida (Sikka Karmik)</i>  | <i>GH-01C, Sector 78</i><br><i>STP under construction no maintenance staff available</i>  |
|           | 10. | <i>M/s Orian infrabuild Pvt. Ltd. Plot no. GH-01/B, Sector 78, Noida (Aditya Urban Casa)</i>                           | <i>GH-01/B Sector 78</i><br><i>STP not constructed</i>  |
|           | 11. | <i>M/a Aims Max Gardenia Developers Pvt. Ltd. GH-01, Ecocity Sector 75, NOIDA</i>                                      | <i>GH-01, Sector 75</i><br><i>STP not functioning properly</i>  |
|           | 12. | <i>Aims Max Gardenia</i>   | <i>Sector 75</i><br><i>STP Not functional</i>   |

|  |     |  |                            |   |
|--|-----|--|----------------------------|---|
|  |     | <b>Developers Pvt. Ltd. GH-08, Sector - 75, NOIDA</b>  |                            |   |
|  | 13. | <b>Aims Max Gardenia Developers Pvt. Ltd. GH-12, Sector - 75</b>   | <b>GH 12 Sector 75</b>     | <b>STP functional but not maintained properly</b> |
|  | 14. | <b>M/s Valuent Developers Pvt. Ltd. Plot No.H - 169, Sector 63, NOIDA (Valuent infra developers)</b>                                 | <b>GH-16 Sector - 75</b>   | <b>Applied for Jal/Sewer connection</b>           |
|  | 15. | <b>M/s Maxbils Construction Pvt. Ltd. Plot No. 17, Eco city, Sector - 75, NOIDA (Max Villas GH-17)</b>                               | <b>GH-17 Sector 75</b>     | <b>STP not properly</b>                           |
|  | 16. | <b>M/s paramount towers Pvt. Ltd, plot no. GH-06, Sector 137. Noida, Paramound floraville</b>  | <b>GH-06 Sector - 137</b>  | <b>STP Found working</b>                          |
|  | 17. | <b>M/s Gulshan Homes Pvt. Ltd. Plot No. GH 07A, Sector 137 Noida (Gulshan Vivante)</b>   | <b>GH07A Sector 137</b>    | <b>STP found working</b>                          |
|  | 18. | <b>M/s Imperiaial Housing Ventures Pvt. Ltd. 11<sup>th</sup> Floor, Paras Twin Tower, Sector 54, Gurgaon, Haryana (paras Tierra)</b> | <b>GH-01 Sector 137)</b>   | <b>STP Not working properly</b>                   |
|  | 19. | <b>M/s Logix Infrastructure Pvt. Ltd. GH-02 Sector 137 (Blossom County)</b>  | <b>GH-02 Sector - 137</b>  | <b>STP not found working in full capacity</b>     |
|  | 20. | <b>M/s Supertech Ltd, Plot no, GH 3 Sector 137, Noida (Supertech GP housing)</b>   | <b>GH-03 Sector - 137</b>  | <b>STP found working</b>                          |
|  | 21. | <b>Purvanchal Society GH-4</b>   | <b>Sector 137</b>          | <b>STP found working</b>                          |
|  | 22. | <b>M/s Exotica Housing, Pvt. LTd. GH-05A, Sector 137, (Frexco PRasco)</b>  | <b>GH-05A Sector - 137</b> | <b>STP found working</b>                          |
|  | 23. | <b>M/s M.P.G. Realty Pvt. Ltd. Plot No. GH-07B, Sector - 137, Noida (Ajnara Home)</b>  | <b>GH-07B Sector - 137</b> | <b>STP note found working</b>                     |
|  | 24. | <b>M/s I.V. County Pvt. Ltd, Plot No. GH-05, Sector</b>  | <b>GH-05 Sector - 121</b>  | <b>STP is functional but not performing</b>       |

|     |  |                           |                             |  |   |
|-----|--|---------------------------|-----------------------------|--|---|
|     |  |                           | - 121, Noida (Cleo Country) |  | standard norms                                      |
| 25. | M/s Ajnara India Pvt. Ltd. Plot no. GH-01B Sector 74, Noida (Ajnara grand heritage)                            | GH-01B Sector 74          |                             |  | STP is functional but not performing standard norms |
| 26. | M/s J.M. Housing Ltd. Plot No. GH 01C, Sector 76, NOIDA (JM Orchid)  | GH-01C Sector 76          |                             |  | STP functional                                      |
| 27. | Antriksh Forest  | Sector 77                 |                             |  | STP not functional                                  |
| 28. | M/s Great Value Projects India Ltd. plot no. GH-02, Sector 107, NOIA (Great Value Sharnam Society)             | GH-02 Sector - 107        |                             |  | STP functional                                      |
| 29. | M/s Sunworld Developers Pvt. Ltd. Plot No. GH-01B, Sector 107) Noida (Sunworld Vanalika Society)               | GH-01B Sector - 107       |                             |  | STP not functional                                  |
| 30. | Prateek Infraprojects India Pvt. Ltd. GH-01A (Beta-2), Sector - 107, Noida (Prateek Edifice Society)           | GH-01A Beta-02 Sector 107 |                             |  | STP functional                                      |
| 31. | Lotus Boulevard Plot no. 3   | Sector 100                |                             |  | STP functional                                      |
| 32. | M/s Claud -9 Projects Pvt. Ltd. Plot no. 229, Okhla Industrial Estate, New Delhi (Lotus Spacia Plot No. GH-02) | GH-02 Sector 100          |                             |  | STP not functioning properly                        |
| 33. | M/s Sethi Buildwell Pvt. Ltd. Plot NO. GH-01B, Sector 107, NOIDA( Shathi Max')                                 | GH-02B Sector 76          |                             |  | STP not functional                                  |
| 34  | M/s Logix Infratech Pvt. Ltd. No. GH-01, Sector - 143, NOIDA (Logix Blossom Green)                             | GH-01 Sector - 143        |                             |  | STP not functional                                  |
| 35. | M/s Logix City Developers Pvt. Ltd. Plot No. GH-02, Sector 143, NOIDA (Logix Blossom Zest)                     | GH-02 Sector - 143        |                             |  | STP not functional                                  |
| 36. | M/s Amrapali Zodiac Developers Pvt. Ltd. Plot No. GH-03  | GH-03 Sector - 120        |                             |  | STP is not working                                  |

|  |     |  |                                   |  |
|--|-----|--|-----------------------------------|--|
|  |     | <b>Sector 120<br/>NOIDA<br/>Amrapali<br/>Zodiac</b>  |                                   |  |
|  | 37. | <b>M/s RG<br/>Residency<br/>Pvt. Ltd. Plot<br/>NO. GH-02<br/>NOIDA, RG<br/>Buildtech</b>   | <b>GH-02<br/>Sector<br/>120</b>   | <b>STP is not<br/>working</b>  |
|  | 38. | <b>M/s Gaursons<br/>India Pvt. Ltd.<br/>Plot No. GH-<br/>04<br/>Sector 119,<br/>NOIDA (Gaur<br/>Grander)</b>                         | <b>GH-04<br/>Sector-<br/>119</b>  | <b>STP Not<br/>constructed</b>   |
|  | 39. | <b>M/s Eldeco<br/>Infrastructure<br/>&amp; Properties<br/>Ltd. Plot No.<br/>GH-03, Sector<br/>119 NOIDA<br/>(Eldco<br/>Amantran)</b> | <b>GH-03<br/>Sector -<br/>119</b> | <b>STP is in<br/>running<br/>condition but<br/>maintenance<br/>records are<br/>not provided</b>                              |
|  | 40. | <b>Gulshan<br/>Ikwana<br/>Sector, 143,<br/>NOIDA</b>   | <b>Sector -<br/>143</b>           | <b>STP<br/>functional</b>  |
|  | 41. | <b>Aditya<br/>Celebration<br/>Sector - 76<br/>NOIDA</b>  | <b>Sector<br/>76</b>              | <b>STP not<br/>constructed<br/>sewer line of<br/>society<br/>connected to<br/>main sewer<br/>line of NOIDA<br/>Authority</b> |
|  | 42. | <b>Prateek<br/>Winsteria<br/>Sector - 77,<br/>NOIDA</b>  | <b>Sector<br/>77</b>              | <b>STP working<br/>properly</b>  |
|  | 43. | <b>Elite Homez<br/>Sector -77<br/>NOIDA</b>  | <b>Sector<br/>77</b>              | <b>STP found in<br/>proper<br/>functional</b>  |
|  | 44. | <b>Civitech<br/>Sampriti<br/>Sector -77<br/>NOIDA</b>  | <b>Sector<br/>77</b>              | <b>STP found in<br/>proper<br/>functional</b>  |
|  | 45. | <b>Grahpraresh<br/>Sector 77<br/>NOIDA</b>   | <b>Sector<br/>77</b>              | <b>STP found in<br/>proper<br/>functional</b>  |
|  | 46. | <b>Ajnara<br/>Defodril<br/>Sector - 137,<br/>NOIDA</b>   | <b>Sector<br/>137</b>             | <b>STP found<br/>working</b>   |
|  | 47. | <b>Supertech<br/>Ecocity,<br/>Sector - 137,<br/>NOIDA</b>  | <b>Sector<br/>137</b>             | <b>STP found<br/>working</b>   |
|  | 48. | <b>Prateeck<br/>Stylon</b>   | <b>Sector<br/>45</b>              | <b>STP found<br/>working</b>   |
|  | 49. | <b>NRI city<br/>Homes</b>  | <b>Sector<br/>45</b>              | <b>STP found<br/>working</b>   |
|  | 50. | <b>Gardenia</b>  | <b>Sector<br/>46</b>              | <b>STP found<br/>working</b>   |
|  | 51. | <b>Jalvayu<br/>Tower</b>   | <b>Sector<br/>47</b>              | <b>STP found<br/>working</b>   |
|  | 52. | <b>Eldeco<br/>Ananda<br/>Apartment</b>   | <b>Sector<br/>48</b>              | <b>STP found<br/>working</b>   |
|  | 53. | <b>Pearls<br/>Gateway<br/>Towers</b>   | <b>Sector<br/>44</b>              | <b>STP found<br/>working</b>   |
|  | 54. | <b>Assotech</b>  | <b>Sector<br/>44</b>              | <b>STP found<br/>note working</b>  |
|  | 55. | <b>Steller Green</b>   | <b>Sector<br/>44</b>              | <b>STP found<br/>working</b>   |
|  | 56. | <b>Antkrish<br/>Kanball</b>  | <b>Sector<br/>77</b>              | <b>STP under<br/>construction</b>  |
|  | 57. | <b>Amrapali<br/>Shaphire 1&amp;2</b>   | <b>Sector -<br/>45</b>            | <b>STP found<br/>working</b>   |
|  |     |  |                                   |  |

|    |  |   |
|----|--|---|
|    |  | <p><i>Inspection of societies has been affected due to Covid-19, that is the reason of slow progress, so it is requested to kindly grant extra time in addition to compliance period. Inspection report and photographs enclosed <b>(Annexure-A)</b>.</i></p>   |
| 2. | <p><i>In compliance with Hon'ble NGT directions and Water Prevention Act-1976, joint inspections with UPPCB team will be conducted at different sections/location and violators to be appropriately prosecuted. Committee shall also check untapped sewer lines of individuals/builders/villagers and same shall be informed to concerned department for necessary action. (Time Required- 1 year)</i></p> | <p><i>Joint Inspection with UPPCB team is carried out as per norms prescribed by State Pollution Control Board at different industries</i></p> <p><i>Location:-</i></p> <ol style="list-style-type: none"> <li><i>1. M/s Sandeep Paper Mill, sector-06: STP found functional and performing standard norms prescribed by CPCB copy of the consolidated report is attached herewith for your kind perusal please.</i></li> <li><i>2. M/s Body Care International Ltd., D-247/13, sector-63: There was no arrangements for treatment of untreated effluent. Untreated effluent was discharging into Noida drain. A sample of untreated effluent analyzed and found not match the prescribed limits. Report sent to board head office to penalize the industries for non-compliance of water (Pollution control) article 1974.</i></li> <li><i>3. M/s Halidram Snacks Pvt. Ltd., plot no. -A-11, sector - 68: ETP found functional and report of treated water analyzed and found according to norms as prescribed by CPCB.</i></li> </ol> <ol style="list-style-type: none"> <li><i>1. M/s Anand Electro Platers, B-87-88, SECTOR -10: ETP found functional and sample of treated water has been analyzed at regional office and found as per norms as prescribed by CPCB.</i></li> <li><i>2. Location Village -Harola, Notice has been issued to villagers to stop discharging polluted water in drains. They are directed connect to waste water pipes into existing sewer lines. Notice issued to 1. House No. -V-71, 2. House No. -V-68,</i></li> </ol> |

|    |  |  |
|----|--|--|
|    |  | 3. House No. V-17 of village Harola <b>(Annexure-B)</b>  |
| 3. | Proposals for strengthening of existing sewerage network amounting to Rs. 19.77 Cr. have been submitted and same are to be executed on priority basis. (Time Required – 2 years)   | There are total 10 (ten) identified, sewer strengthening works. Five works out of eight are almost completed, that is of 65 percent of the targeted. The updated information sheet having details of works is attached herewith as <b>(Annexure-C)</b>   |
| 4. | Noida Authority in anticipation of future projected load has already planned to put more STPs of capacity 180MLD as planned by WAPCOS in place to accommodate the future load of sewerage carried out against encroachers on embankment of drains and same has been maintained. So disposal of untreated waste water into drains has been stopped. All encroachments on the embankment of these 30 drains will be removed within next one year. (Time Required – 1 year) | <p>Noida has 6 nos. of STPs constructed at different places. Existing Capacity of STPs is 231 MLD. Sewage generation on an average is 215 MLD. (Present)</p> <p>The STP project having capacity 180 MLD is in progress.</p> <p>Vide C.B. No mention below</p> <p>C.B. No. 14/GM(R)/AO/SM (OA)/2020-21 Dt. 03.09.2020 for 80 MLD</p> <p>C.B. No. 15/GM(R)/AO/SM (OA)/2020-21 Dt. 03.09.2020 for 100 MLD</p> <p>The drives to ensure encroachment free drains embankments are carried by the respective Work Circle incharge. The copy of the recent summarized reports with photographs as carried by the respective work circles indicate no encroachment on the drain's embankments are placed herewith as <b>Annexure-F</b> for your ready perusal please.</p> |
| 5. | Noida Authority in anticipation of future projected load has already planned to put more STPs of capacity 180MLD as planned by WAPCOS in place to accommodate the future load of sewerage carried out against encroachers on embankment of drains and same has been maintained. So disposal of untreated waste water into drains has been stopped. All encroachments on the embankment of these 30 drains will be removed within next one year. (Time Required – 1 year) | <p>Noida has 6 nos. of STPs constructed at different places. Existing Capacity of STPs is 231 MLD. Sewage generation on an average is 215 MLD. (Present)</p> <p>The STP project having capacity 180 MLD is in progress.</p> <p>Vide C.B. No mention below</p> <p>C.B. No. 14/GM(R)/AO/SM (OA)/2020-21 Dt. 03.09.2020 for 80 MLD</p> <p>C.B. No. 15/GM(R)/AO/SM (OA)/2020-21 Dt. 03.09.2020 for 100 MLD</p> <p>The drives to ensure encroachment free drains embankments are carried by the respective Work Circle incharge. The copy of the recent</p>   |

|  |  |   |
|--|--|---|
|  |  | <p><i>summarized reports with photographs as carried by the respective work circles indicate no encroachment on the drain's embankments are placed herewith as <b>Annexure-F</b> for your ready perusal please.</i></p> |
|--|--|---|

8. Learned counsel for the NOIDA stated that only 57 societies have been inspected out of 95 and the remaining societies are to be inspected. Wherever deficiencies have been found, action has been initiated and reference has also been made to the State PCB. Learned counsel for the DJB states that action has been taken on its part. However, there is no response from the EDMC and the Secretary Urban Development, UP in respect of action at Khoda Nagar Parishad, Makaanpur.

9. Learned counsel for EDMC, on instructions says, that there is a proposal to shift the dairies but that is not possible in absence of land. We find this excuse untenable only to avoid responsibility. The plea raised is not a justification for permitting violation of law by the dairies to the detriment of the rights of the citizens. To enforce rule of law and prevent the causing of pollution and hazard to the health of the inhabitants, activities operating in violation must be forthwith stopped and compensation recovered for the violations. Prosecution may be initiated and source of pollution may be closed. DPCC must also take necessary action on its part. If the EDMC remains non-compliant, the Commissioner will be personally held responsible. Let the compliance report be file within two months by e-mail at [judicial-ngt@gov.in](mailto:judicial-ngt@gov.in) preferably in the form of searchable PDF/ OCR Support PDF and not in the form of Image PDF.

10. With regard to the action against erring high-rise buildings in Noida, further steps be taken expeditiously and compensation assessed



by a joint Committee of CPCB, State PCB, NOIDA and District Magistrate, NOIDA within three months.

11. The Secretary, Urban UP may also ensure compliance of action by the Nagar Palika Parishad, Khoda Makanpur.

12. Let further compliance reports be filed before the next date by e-mail at [judicial-ngt@gov.in](mailto:judicial-ngt@gov.in) preferably in the form of searchable PDF/OCR Support PDF and not in the form of Image PDF by CPCB, Noida, UP PCB, EDMC, DPCC, Secretary Urban Development UP. A copy of this order be sent to them by e-mail.

List again on 22.03.2021.

Adarsh Kumar Goel, CP

S.K. Singh, JM

Dr. S.S. Garbyal, EM

Dr. Nagin Nanda, EM

November 06, 2020  
Original Application No. 1002/2018  
A